

2021 Consumer Confidence Report Data HARRISON UTILITIES - FKA WAVERLY SD, PWS ID: 40800760

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Dlaim ntawv tshaabzu nuav muaj lug tseemceeb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ib tug kws paub lug thaam.

Water System Information

If you would like to know more about the information contained in this report, please contact Tom Van Zeeland at (920) 731-0002.

Opportunity for input on decisions affecting your water quality

The Harrison Village Boards meets at 6:00 PM on the last Tuesday of each month, as well as the 2nd Tuesday as necessary.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Source	Depth (in feet)	Status
2	Purchased Surface Water		Active

Purchased Water

PWS ID	PWS Name
44503338	APPLETON WATERWORKS

To obtain a summary of the source water assessment please contact, Tom Van Zeeland at (920) 731-0002.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAL	Health Advisory Level: The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
SMCL	Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
HAA5 (ppb)	H-10	60	60	20	13 - 18		No	By-product of drinking water chlorination
TTHM (ppb)	H-10	80	0	36.7	26.3 - 33.6		No	By-product of drinking water chlorination
HAA5 (ppb)	T-1	60	60	15	9 - 16		No	By-product of drinking water chlorination
TTHM (ppb)	T-1	80	0	27.1	20.6 - 29.5		No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.0771	0 of 20 results were above the action level.	8/14/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
							wood preservatives
LEAD (ppb)	AL=15	0	0.00	0 of 20 results were above the action level.	8/12/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Harrison Utilities - Fka Waverly Sd is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Presence of Other Contaminants

Monthly sampling for bacterial contamination is conducted. Samples are tested quarterly for disinfection by-products. Three times each week the chlorine residuals are tested. Harrison Utilities conducts a lead and copper sampling program.

Purchased Water

Our water system purchases water from APPLETON WATERWORKS. In addition to the detected contaminants listed above, these are the results from APPLETON WATERWORKS.

(table on next page)

Appleton Water Treatment Facility - Safe Water on Tap

The table below identifies the regulated substances detected in the 2021 Appleton water regulatory testing. Every regulated substance that is detected, even in trace amounts, is listed here. The levels detected for these contaminants were all below levels allowed by state and federal regulations in 2021.

Contaminant (units)	MCL	MC LG	Level Found	Range	Violation	Typical Source of Contaminant
Atrazine (ppb) (2020)	3	3	0.1	0.0-0.1	None	Runoff from herbicides used on row crops.
Barium (ppm)	2	2	0.005	0.005	None	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Copper (ppm) (2020)	AL-1.3	1.3	0.053	0 of 30 results were above the action level	None	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
Fluoride (ppm)	4	4	0.59	0.55-0.68	None	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. SMCL = 4.0 ppm
Haloacetic Acid (HAA5) multiple sites (ppb)	60	60	15 (average)	9-19	None	By-product of drinking water chlorination.
Hexachlorocyclopentadiene (ppb) (2020)	50	50	0.0069	0.0-0.0069	None	Discharge from chemical factories.
Lead (ppb) (2020)	AL=15	0	11	0 of 30 results were above the action level	None	Corrosion of household plumbing systems; Erosion of natural deposits
Metolachlor (Dual)(ppb) (2020)	n/a	n/a	0.03	0.03-0.03	None	n/a
Nitrate (NO3-N) (ppm)	10	10	0.15	0.15	None	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radium (226 + 228) (pCi/l) (2020)	5	0	0.71	0.33-0.38	None	Erosion of natural deposits
Sodium (ppm)	n/a	n/a	12	12	None	n/a
Sulfate (ppm)	n/a	n/a	32	32	None	Runoff/leaching from natural deposits, industrial wastes
Aluminum (ppm) (2020)	n/a	n/a	0.04	0.04	None	Runoff/leaching from natural deposits
Chloride (ppm) (2020)	n/a	n/a	17	17	None	Runoff/leaching from natural deposits, road salt, water softeners
Trihalomethanes, Total (TTHM) multiple sites (ppb)	80	0	29 (average)	20-35	None	By-product of drinking water chlorination Reported is the highest annual location average and largest range from the multiple sites.
Combined Uranium (ppb) (2020)	30	0	0.4	0.4	None	Erosion of natural deposits.

Definitions and Notes

AL – Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Haloacetic Acids – Total of Mono-, di-, and tri-chloroacetic acid; mono- and di-bromoacetic acid; and bromochloroacetic acids

MCL – Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG – Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

n/a – Not Applicable

pCi/l – Picocuries per liter (a measure of radioactivity)

ppb – Parts per billion, or micrograms per liter (ug/l)

ppm – Parts per million, or milligrams per liter (mg/l)

SMCL – Secondary Maximum Contaminant Level: Inorganic chemicals that are not hazardous to health but may be objectionable to an appreciable number of persons.

Trihalomethanes, Total – Total of chloroform, bromo-dichloromethane, dibromochloromethane and bromoform

In accordance with NR 810.29, Wisconsin Administrative Code, the treated surface water is monitored for turbidity to confirm that the filtered water is less than or equal to 0.3 NTU in at least 95 percent of the measurements taken each month and never exceeds 1 NTU. In 2021, the highest single entry point turbidity measurement was 0.04 NTU. The lowest monthly percentage of samples meeting the turbidity limits was 100 percent.

Unregulated Compound Monitoring Requirement

Unregulated contaminants are those for which the USEPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. The Appleton Water Utility participated in this monitoring. See the Water Utility website and the follow URL for more information:

<https://www.appleton.org/home/showdocument?id=22501>